



Power Oscillation Damping from Offshore Wind Farms Connected to HVdc via Diode Rectifiers

Saborío-Romano, Oscar; Bidadfar, Ali; Göksu, Ömer; Zeni, Lorenzo; Cutululis, Nicolaos Antonio

Published in:
Energies

Link to article, DOI:
[10.3390/en12173387](https://doi.org/10.3390/en12173387)

Publication date:
2019

Document Version
Publisher's PDF, also known as Version of record

[Link back to DTU Orbit](#)

Citation (APA):
Saborío-Romano, O., Bidadfar, A., Göksu, Ö., Zeni, L., & Cutululis, N. A. (2019). Power Oscillation Damping from Offshore Wind Farms Connected to HVdc via Diode Rectifiers. *Energies*, 12(17).
<https://doi.org/10.3390/en12173387>

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

Article

Power Oscillation Damping from Offshore Wind Farms Connected to HVDC via Diode Rectifiers

Oscar Saborío-Romano ^{1,*} , Ali Bidadfar ¹ , Ömer Göksu ¹ , Lorenzo Zeni ²
and Nicolaos A. Cutululis ¹ 

¹ Department of Wind Energy, Technical University of Denmark, Building 115, Risø Campus, Frederiksborgvej 399, 4000 Roskilde, Denmark

² Ørsted Offshore, Nesa Allé 1, 2820 Gentofte, Denmark

* Correspondence: osro@dtu.dk

Received: 5 July 2019; Accepted: 21 August 2019; Published: 2 September 2019



Abstract: Diode rectifiers (DRs) have elicited increasing interest from both industry and academia as a feasible alternative for connecting offshore wind farms (OWFs) to HVDC networks. However, before such technology is deployed, more studies are needed to assess the actual capabilities of DR-connected OWFs to contribute to the secure operation of the networks linked to them. This study assessed the capability of such an OWF to provide support to an onshore AC network by means of (active) power oscillation damping (POD). A semi-aggregated OWF representation was considered in order to examine the dynamics of each grid-forming wind turbine (WT) within a string when providing POD, while achieving reasonable simulation times. Simulation results corroborate that such an OWF can provide POD by means of OWF active power controls similar to those developed for OWFs connected to HVDC via voltage source converters, while its grid-forming WTs share the reactive power consumption/production and keep the offshore voltage frequency and magnitude within their normal operating ranges. Open-loop test results show that such capability can, however, be restricted at operating points corresponding to the lowest and highest values of active power output.

Keywords: diode-rectifier-based HVDC transmission; grid-forming wind turbine control; offshore wind energy integration; power oscillation damping

1. Introduction

Europe's offshore wind resources cannot be fully exploited without the development of the necessary electrical infrastructure to connect offshore wind farms (OWFs) and onshore networks. Until now, only a few OWFs export their production through HVDC, while the majority are connected via traditional HVAC [1]. However, the amount of HVDC-connected OWFs is widely expected to increase, as the size and distance from shore of new OWFs increase, and the associated costs decrease [2,3].

HVDC transmission technology using voltage source (forced-/self-commutated) converters (VSCs), based on insulated-gate bipolar transistors, has undergone remarkable development since its introduction in 1997 [4]. Such technology still faces costs and losses higher than those associated with the more common, mature one employing (phase-controlled) line-commutated converters, based on thyristors (in a current source converter topology), which are largely employed for bulk power transmission [3,5]. Nevertheless, VSC-based HVDC transmission (VSC-HVDC) offers advantages such as fast reversibility of active power flow, independent control of active and reactive power, smaller footprints, and the (grid-forming) capability to form AC networks, i.e. to control their AC-side voltage magnitude and frequency (which allows them to operate without the need of a strong AC

grid) [4]. Because of such advantages, the use of VSC-based offshore HVDC terminals has made it possible to develop HVDC-connected OWFs with the prevailing grid-following approach to controlling wind turbines (WTs), in which WTs rely on other (grid-forming) units (e.g. VSC-based offshore HVDC terminals) forming their AC network [1].

Recently put forward, (uncontrolled, line-commutated) diode rectifiers (DRs) have elicited increasing interest from both industry and academia as a feasible alternative for connecting OWFs to HVDC networks [6–11]. DR-based offshore HVDC terminals offer advantages such as lower costs, higher efficiency, smaller footprints and higher reliability [8,10]. However, since diodes are passive devices, such offshore HVDC terminals are inherently devoid of the grid-forming capability of VSCs. WTs have therefore been suggested as feasible candidates to take over such duty. This entails fundamentally different WT and WF controls, changing their control approach from that of grid-following units to that of grid-forming units [6,9].

HVDC-connected OWFs and the corresponding HVDC power transmission networks can be required to contribute to the secure operation of the onshore AC networks connected to them by means of e.g., fault ride-through, black start and restoration, reactive power/alternating voltage control, active power/frequency control and rotor angle stability-related control. Rotor angle stability-related control can include avoiding loss of synchronism and damping electromechanical oscillations, also known as *power oscillation damping* (POD) [3,12]. The capabilities of VSC-HVDC-connected OWFs and the corresponding HVDC power transmission networks to provide such services are well established. However, more studies are needed to assess the actual capabilities of DR-connected OWFs to contribute in the provision of such services before such technology is deployed [12,13].

The impact of AC-connected WFs on power oscillations has been reviewed in [14], where focus has been given to the contribution or damping of the oscillations, and to the resulting oscillations inside the WTs. By considering the full layout of the collector grid and individual representation of the WTs in such a WF, the impact of the controls in each WT on oscillatory modes has been assessed in [15], and it has been shown that park level control is possible and that the level of WF model aggregation has a limited impact on the resulting damping. Recommendations have been given in [16] for selecting the best input–output signal pair for the provision of POD by such WFs, based on a comparison of different analysis techniques that considers both controllability, observability and input–output interactions. In [17], the implementation of POD controls on VSC-HVDC-connected OWFs has been studied, design guidelines have been derived for the corresponding controllers, the effect of voltage regulators has been analysed, and other practical implementation aspects have been discussed. In [18], it has been shown for such OWFs that supplementary controls in the VSC-based onshore terminal alone can result in undesirable voltage variations in the onshore ac network and that modulation of the OWF active power output alone can be inadequate due to the limited overloading capability of the WTs, and a decentralised coordinated controller has been proposed to overcome such limitations.

The present study assessed the actual capability of an OWF to provide POD to an onshore AC network by means of active power modulation, when connected through an HVDC link having a DR-based offshore terminal and a VSC-based onshore terminal. The study also examined the compatibility of corresponding higher-level controls previously devised for VSC-HVDC-connected OWFs [17]. Through such controls, the OWF modifies its active power output according to the onshore frequency signals directly communicated to it. Any contribution of the onshore HVDC terminal in the provision of POD is outside the scope of the study, as are also the impact and benefits of such service on the onshore synchronous area stability.

Previous work [19] consisted of closed-loop tests using models and grid-forming WT front-end converter (FEC) controls based on those in [6–8], and a single-turbine aggregated representation of the OWF. Such controls rely on communication for a centralised control of the offshore AC network voltage and do not deal with the synchronisation of the WT FECs, whereas the single-turbine aggregated OWF model does not provide enough insight into the dynamics within the OWF.

This work extended the analysis to both open- and closed-loop tests using more detailed models based on those in [20] and a semi-aggregated representation of the OWF. Such OWF representation provides insight into the dynamics of the WTs within a string by representing them in detail, while keeping reasonable simulation times. The contemplated distributions of aerodynamic power from the wind available to each WT frame the study in more realistic operating conditions. The open-loop tests facilitate the evaluation of the WF's compliance with the corresponding connection requirements for the provision of POD. Moreover, the considered grid-forming WT FEC controls are based on those in [11], which rely solely on local measurements and enable the synchronisation of the WT FECs by means of a distributed phase-locked-loop-based (PLL-based) frequency control algorithm.

Results of the performed dynamic simulations for the different operating conditions corroborate that such an OWF can provide POD by means of OWF active power controls similar to those developed for OWFs connected to HVDC via VSCs, while its grid-forming WTs share the reactive power consumption/production and keep the offshore frequency and voltages within their normal operating ranges. The results of the closed-loop tests show that the damping of onshore power oscillations can be increased by having DR-connected OWFs employ such strategies to modulate their active power output in response to the onshore signals directly communicated to them. The results of the open-loop tests show that such capability can, however, be restricted at operating points corresponding to the lowest and highest values of active power output.

The rest of the paper is organised as follows. In Section 2, the investigated system is described and the main control algorithm is detailed. In Section 3, some of the considered cases are described, and corresponding simulation results are presented and discussed. Finally, concluding remarks are made in Section 4.

2. Modelling and Control

Figure 1 shows an overview of the studied system. The system is based on that described in [13,20] and consists of a 400 MW WF connected to an onshore AC network by means of a monopolar HVDC link. Balanced/symmetric operation is assumed. The onshore AC network is represented by a lumped three-phase 1200 MW synchronous machine (SM) with its governor, turbine, exciter and automatic voltage regulator (AVR), and a lumped three-phase 80 MW resistive load, connected to an infinite bus through a transmission line. The corresponding SM and transmission line parameters have been set in a reasonable way, so as to achieve oscillations with frequencies around 1 Hz. The share of wind power generation at the connection point is 25 %, i.e., the WF is rated at 400 MW, for a total installed capacity at the connection point of 1600 MW. The VSC-based onshore HVDC terminal controls the voltage on its DC terminals and the reactive power injected into the onshore AC network. The offshore HVDC terminal, labelled in Figure 1 as *DR Platform*, consists of two (uncontrolled, line-commutated) diode-based 12-pulse rectifiers (DRs) connected in series, with corresponding reactive power compensation and filter bank on their AC side.




Figure 1. Overview of the studied system.

The WF has 50 type-4 (full-converter) 8MW WTs, laid out in six strings. The first string is comprised of WTs 1–9, which are represented in detail. The second string, consisting of WTs 10–18, is aggregated into an equivalent 72 MW WT and corresponding cable equivalent π circuit using the method proposed in [21]. Likewise, the other four strings, comprising WTs 19–50, are aggregated into an equivalent 256 MW WT and corresponding cable equivalent π circuit.

For computational efficiency, dynamics in the WT DC link and behind it are not considered, and its voltage is thus assumed constant (ideally regulated by the back-end/machine-side converter). Pulse width modulation (PWM) is assumed to be done in the linear range, switching effects and any delay due to implementation of the PWM are neglected, and average value models are used to represent all VSCs. Focus is given to dynamics not faster than the VSC (inner/lower) current control loops, the fastest of which are designed to have a bandwidth of 200 Hz.

2.1. Wind Turbine Front-End Converter Controls

The front-end (line-side) network in the k th wind turbine(s), WT_k , is shown in Figure 2, while Figure 3 depicts the corresponding FEC controls. Such controls are based on those proposed in [11] and are implemented on a rotating reference frame (RRF) oriented on the voltage at the filter capacitor, $U_{T,k}$.




Figure 2. WT_k front-end (line-side) network.




Figure 3. WT_k front-end converter controls.

In each WT front-end network, the filter capacitor voltage direct (d) and quadrature (q) axis components, $U_{Td,k}$ and $U_{Tq,k}$, respectively, are regulated by the FEC lower/inner cascaded current and voltage control loops to follow the corresponding references, $U_{Td,k}^*$, $U_{Tq,k}^*$, respectively, while keeping

the FEC output current, $I_{T,k}$, within its limits. $U_{Td,k}^*$ consists of two components: the offshore AC network voltage set point, U_0 , common to all WTs, and a component individual to each WT, which is altered to control the FEC active power output, $P_{T,k}$. In an additional control loop based on the FEC PLL, a proportional (P) controller manipulates $U_{Tq,k}^*$ to regulate the FEC (angular) frequency, ω_k . The reference to such additional loop, ω_k^* , also consists of two components: the offshore AC network (angular) frequency set point, ω_0 , common to all WTs, and a component individual to each WT, which is altered to control the FEC reactive power output, $Q_{T,k}$. When the WF is exporting power, the FEC upper/outer control loops in each WT regulate $P_{T,k}$ and $Q_{T,k}$ as follows. A proportional-integral (PI) controller regulates $P_{T,k}$ to follow the corresponding reference, $P_{T,k}^*$, whereas $Q_{T,k}$ is controlled by a P regulator (reactive-power-frequency droop) with a given reference, $Q_{T,k}^*$, so that the reactive power is shared among WT FECs (avoiding overcurrents and reactive current circulation).

2.2. Wind Farm Active Power Control

To study the capability of such a WF to provide POD to an onshore AC network, the model is extended to include the supervisory active power control (APC) at plant level shown in Figure 4, based on that proposed in [17] for OWFs connected to HVDC via VSCs. In normal operation, the PI regulator alters the WF active power dispatch, P^* , so as to have the WF active power output, P_F , follow its reference, P_F^* . A first-order low-pass filter (LPF) is applied to the corresponding measurement signal. Hardware and control limits are modelled by means of corresponding restrictions on the regulator output value, \hat{P} , and its rate of change, $d\hat{P}/dt$. Proportional WF generation dispatch is used. In doing so, P^* is divided by the overall aerodynamic power available from the wind, P_{ava} , to generate the WF active power dispatch coefficient, κ_{disp} . The active power set point of each WT is then set as the product of the corresponding aerodynamic power available from the wind, $P_{ava,k}$, and the active power dispatch coefficient, i.e., $P_{T,k}^* = \kappa_{disp} P_{ava,k}$.




Figure 4. Wind farm active power control; parameter values given in Table A1.

The coordinator of the WF and offshore transmission system (WF-OTS coordinator) and/or the system operator are assumed to calculate and monitor the active power flowing from the SM into the corresponding onshore bus, P_{on} , from the alternating voltage and current measured at the SM terminals. The WF-OTS coordinator and/or the system operator are also assumed to detect onshore power oscillations, generate a corresponding signal (in per unit, on the WF base), ΔP_{on} , and send it to the WF with a delay of 100 ms, together with the activation of a flag, F_{POD} .

Upon the activation of F_{POD} , the controller switches to POD control mode. In such mode, \hat{P} is frozen, and an additional oscillatory/modulating (active) power signal, $\Delta \hat{P}$, is superimposed, $P^* = \hat{P}_0 + \Delta \hat{P}$. Since $\Delta \hat{P}$ does not entail an additional net energy delivery to the onshore AC network, no preventively curtailed operation has been considered in the corresponding studies. The WTs are thus briefly overloaded during the positive semi-period of $\Delta \hat{P}$ and recover their speed during its

negative semi-period. In POD control mode, the restrictions imposed on the rate of change of P^* are considered to be less stringent than those usually imposed by the WTs. This is necessary for POD to be provided with a certain minimum performance [17,19].

When evaluating the WF's compliance with grid code requirements for the provision of POD, input port 0 is selected in switch $S_{\Delta\hat{P}}$, so that $\Delta\hat{P}$ is determined by an external sinusoidal signal generated in accordance with the requirements, $\Delta\hat{P} = \Delta\hat{P}_{OL} = (0.1 \text{ pu}) \cos(2\pi f_{OL}t)$, where $f_{OL} \in [0.3, 2] \text{ Hz}$ is the frequency of such external modulating signal [13,22]. When providing POD to the onshore AC network, input port 1 in switch $S_{\Delta\hat{P}}$ is selected, so that $\Delta\hat{P}$ is based on ΔP_{on} , $\Delta\hat{P} = \Delta\hat{P}_{CL}(\Delta P_{on})$. In this way, the WF modulates its active power output so as to produce damping torque: an electrical torque component in phase with the SM speed deviation, $\Delta\omega_{SM}$, increasing the decay rate of the oscillations as a result. The corresponding phase lead compensator provides the necessary phase shift (around 90°) to align ΔP_{on} with $\Delta\omega_{SM}$ (and thus with the damping torque). The gain k_{POD} regulates the magnitude of the control action. Values for the wind farm active power control parameters and limits are given in Table A1.

3. Simulation Results

Results of the performed dynamic simulations are presented in Figures 5–13. The results illustrated in Figures 5–10 correspond to the open-loop tests, discussed in Section 3.1, whereas those depicted in Figures 11–13 correspond to the closed-loop tests, discussed in Section 3.2.

Table 1 details the wind speed scenarios considered in the simulations. The results corresponding to the medium wind speed scenario are similar to those corresponding to the medium-low wind speed scenario and are thus omitted. Wind speed (and the aerodynamic power available from it) was considered constant in each simulation. The considered individual WT operating points in Table 1 take into account the wind speed deficit due to the aerodynamic interaction between WTs. In principle, $P_{ava,k}$ decreases along the string in the wind speed direction [23].

All (equivalent) WT front-end networks and corresponding converter controls have the same parameter per-unit (pu) values. Moreover, $U_0 = 0.86 \text{ pu}$, $\omega_0 = 1 \text{ pu}$ and $Q_{Tk}^* = 0$ for all of them. The wind farm active power control parameters and limits used in the simulations are given in Table A1. No minimum limit above zero production (as given in [13]) was imposed on the WF, so as to study the WF response also at operating points near zero production. The onshore HVDC terminal kept the HVDC link voltage close to the corresponding set point throughout all simulations.

Table 1. Wind speed scenarios considered in the simulations.

Wind Speed	P_{ava}	$P_{ava,1}$	$P_{ava,2}$	Aerodynamic Power Available from the Wind [pu]								$P_{ava,10-18}$	$P_{ava,19-50}$
				$P_{ava,3}$	$P_{ava,4}$	$P_{ava,5}$	$P_{ava,6}$	$P_{ava,7}$	$P_{ava,8}$	$P_{ava,9}$			
Low	0.100	0.232	0.086	0.105	0.092	0.086	0.080	0.075	0.072	0.072	0.100	0.100	
Med.-Low	0.400	0.930	0.345	0.421	0.366	0.344	0.318	0.299	0.289	0.289	0.400	0.400	
Medium	0.600	0.987	0.564	0.644	0.586	0.562	0.535	0.515	0.504	0.504	0.600	0.600	
High	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000	1.000	

3.1. Open-Loop Tests

Results of the open-loop tests are shown in Figures 5–10. In such tests, F_{POD} was active and input port 0 was selected in switch $S_{\Delta\hat{P}}$ in the WF APC (Figure 4), so that the APC was in POD control mode and the WF modulated its active power output according to $P^* = \hat{P}_0 + \Delta\hat{P}_{OL} \approx P_{ava} + \Delta\hat{P}_{OL}$. $\Delta\hat{P}_{OL} = 0$ at the beginning of each simulation but changes shortly afterwards to $\Delta\hat{P}_{OL} = (0.1 \text{ pu}) \cos(2\pi f_{OL}t)$. P_{ava} is given by the wind speed scenario (Table 1), whereas the two extreme values given in [13,22] for f_{OL} were considered. Figures 5–7 correspond to $f_{OL} = 0.3 \text{ Hz}$, whereas Figures 8–10 correspond to $f_{OL} = 2 \text{ Hz}$.




Figure 5. Open-loop response at low wind speed; $\Delta \hat{P}_{OL} = (0.1 \text{ pu}) \cos [2\pi (0.3 \text{ Hz}) t]$.




Figure 6. Open-loop response at medium-low wind speed; $\Delta \hat{P}_{OL} = (0.1 \text{ pu}) \cos [2\pi (0.3 \text{ Hz}) t]$.




Figure 7. Open-loop response at high wind speed; $\Delta \hat{P}_{OL} = (0.1 \text{ pu}) \cos [2\pi (0.3 \text{ Hz}) t]$.




Figure 8. Open-loop response at low wind speed; $\Delta\hat{P}_{OL} = (0.1 \text{ pu}) \cos [2\pi (2 \text{ Hz}) t]$.




Figure 9. Open-loop response at medium-low wind speed; $\Delta\hat{P}_{OL} = (0.1 \text{ pu}) \cos [2\pi (2 \text{ Hz}) t]$.




Figure 10. Open-loop response at high wind speed; $\Delta\hat{P}_{OL} = (0.1 \text{ pu}) \cos [2\pi (2 \text{ Hz}) t]$.

The WF response is illustrated by the plots on the left side of each figure, whereas WT responses are depicted by the plots on the right side. Solid and dashed traces in the WT responses—superimposed in the case of the WT_k terminal root mean square (RMS) voltages, U_k —represent the responses of WTs 1 and 9, respectively, located at both ends of the string represented in detail (Figure 1).

As depicted by the top-left plots in each figure, the WF can modulate its active power output, P_F , according to the connection requirements for most of its operating range. Such capability can, however, be restricted at operating points corresponding to the lowest and highest values of P_F , as shown in the top plots in Figures 5a, 7a, 8a and 10a. The nonlinear characteristics of the DR-based offshore HVDC terminal can prevent the WF from achieving $P_F = 0$. This can be observed in Figures 5 and 8, which correspond to the low wind speed scenario: when the DRs stop conducting, P_F saturates at a value above 0 and U_k drops sharply. Moreover, the consumption/production of reactive power, necessary to control the offshore AC network (angular) frequency, ω , can reduce the active power headroom of the corresponding grid-forming WTs. Such reduced active power headroom can prevent the WF from achieving $P_F = 1.1$ pu. This is illustrated by Figures 7 and 10, which correspond to the high wind speed scenario: when the WT FEC output currents, $I_{T,k}$, reach their 1.1 pu limit, P_k and P_F saturate at a value below 1.1 pu.

The nonlinear characteristics of the responses correspond to grid-forming WTs and their FECs reaching the limits imposed on their output current, $I_{T,k}^* \leq 1.1$ pu, and on the rate of change of their active power output, $|dP_{T,k}^*/dt| \leq 1.26$ pu/s. Regardless of the HVDC connection technology and as a natural consequence of proportional dispatch,

$$P_{T,1}^* = \kappa_{\text{disp}} P_{\text{ava},1} = \frac{P_{\text{ava},1}}{P_{\text{ava}}} P^*, \quad 1 \leq \frac{P_{\text{ava},1}}{P_{\text{ava}}} \leq 2.325 \quad (1)$$

with the values of $P_{\text{ava},1}$ and P_{ava} given in Table 1. Equation (1) implies that, even though $P^* \leq 1.1$ pu and $|dP^*/dt| \leq 1.26$ pu/s, the value and rate of change of $P_{T,1}^*$ are greater than such limits in the low, medium-low and medium wind speed scenarios. In other words, greater and faster changes in the active power output are demanded from the most upstream WT when the power available to such WT is greater than the average. As depicted in Figures 6b, 8b and 9b, such changes may not be fully achieved because of WT hardware constraints (represented by the aforementioned limits).

3.2. Closed-Loop Tests

Results of the closed-loop tests are depicted in Figures 11–13. In such tests, input port 1 was selected in switch $S_{\Delta\hat{P}}$ in the WF APC (Figure 4), so that the WF modulated its active power output according to $P^* = \hat{P}_0 + \Delta\hat{P}_{\text{CL}} \approx P_{\text{ava}} + \Delta\hat{P}_{\text{CL}}$. Onshore power oscillations were triggered by means of 80 MW load step changes at $t = 0$.




Figure 11. Wind farm response to onshore (active) power oscillations at high wind speed.




Figure 12. Wind farm response to onshore (active) power oscillations at medium-low and low wind speeds.




Figure 13. WT_k response to onshore (active) power oscillations at medium-low and low wind speeds; solid: $k = 1$, dashed: $k = 9$.

Each figure includes base case responses, corresponding to no POD from the OWF. The (light) grey signals in each figure represent the base case, $\Delta \hat{P} = 0$, while the (dark) red traces illustrate the cases in which the WF contributes to damp the oscillations in P_{on} , $\Delta \hat{P} = \Delta \hat{P}_{CL}$ (ΔP_{on}). To improve the response, the POD control mode was activated at the next zero-crossing of ΔP_{on} after the activation of F_{POD} at $t = 0.5$ s. The results depicted in Figure 11 correspond to the high wind speed scenario, whereas those in Figures 12a and 13a correspond to the medium-low wind speed scenario, and those in Figures 12b and 13b correspond to the low wind speed scenario.

WF responses to onshore (active) power oscillations at high, medium-low and low wind speeds are depicted in Figures 11, 12a and 12b, respectively. The offshore AC network (angular) frequency, ω , and WF reactive power output, Q_F , are only presented in Figure 11b corresponding to the high wind speed scenario. However, similar results have been obtained in the three other wind speed scenarios. As can be seen in Figures 11a and 12, the damping of the onshore (active) power oscillations can be increased by having the OWF modulate its active power output, P_F , in response to the onshore signals directly communicated to it.

WT responses to onshore (active) power oscillations at medium and low wind speeds are illustrated by Figure 13a,b, respectively. Once again, solid and dashed traces—superimposed in the case of U_k —represent the responses of WTs 1 and 9, respectively, located at both ends of the string represented in detail (Figure 1). Similar results were obtained in the other two wind speed scenarios.

3.3. Further Comments

The WT active power outputs, P_k , reflect the assumed distributions of $P_{ava,k}$ (Table 1) and the changes in κ_{disp} when the WF modulates its active power output. Such modulation, illustrated in the top-left plots in Figures 5–10 and the bottom plots in Figure 12, is achieved through changes in U_k , which are one or two orders of magnitude smaller, keeping them within their normal operating range, as depicted in the middle-right plots in Figures 5–10 and the top plots in Figure 13. As can be observed in the bottom-right plots in Figures 5–10 and the bottom plots in Figure 13, the WTs share the reactive power consumption or production (negative or positive values, respectively, of the WT_k reactive power output, Q_k) according to P_k .

The changes in P_F result in proportional changes in the DR reactive power consumption. This is reflected in the changes in the WF reactive power output, Q_F , and offshore AC network (angular) frequency, ω , as depicted in the middle- and bottom-left plots in Figures 5–10 and in Figure 11b. However, such changes are one and three orders of magnitude smaller than those in P_F , respectively, while ω is kept close to 1 pu. That is the result of every grid-forming WT FEC contributing autonomously to regulating ω by means of its corresponding PLL-based (proportional) controller, while sharing the reactive power with the other grid-forming WT FECs by means of its reactive-power-frequency droop.

4. Conclusions

This study assessed the actual capability of an OWF to provide POD to an onshore AC network by means of active power modulation, when connected through an HVDC link having a DR-based offshore terminal and a VSC-based onshore terminal. The study also examined the compatibility of corresponding higher-level controls previously devised for VSC-HVDC-connected OWFs. The analysis performed in previous work was extended to both open- and closed-loop tests using more detailed models, a semi-aggregated representation of the OWF and improved grid-forming WT FEC controls. Such OWF representation provides insight into the dynamics of the WTs within a string by representing them in detail, while keeping reasonable simulation times. The contemplated distributions of aerodynamic power from the wind available to each WT frame the study in more realistic operating conditions. The open-loop tests facilitate the evaluation of the WF's compliance with the corresponding connection requirements for the provision of POD.

The simulation results indicate that the new connection concept (and corresponding changes in WT control) does not impact the capability of OWFs to provide POD—in most of their operating range—by means of OWF active power control strategies similar to those developed for VSC-HVDC-connected OWFs. Closed-loop tests showed that the damping of onshore power oscillations can be increased by having DR-connected OWFs employ such strategies to modulate their active power output in response to the onshore signals directly communicated to them.

While modulating their active power output, the grid-forming WTs share the reactive power consumption/production and keep the offshore voltage frequency and magnitude within their normal operating ranges. The semi-aggregated OWF representation makes it possible to corroborate that for each grid-forming WT within the string represented in detail, while achieving reasonable simulation times. The considered distributions of aerodynamic power from the wind available to each WT frame the study in more realistic operating conditions.

Open-loop tests showed that such OWFs can modulate their active power output according to the connection requirements for most of their operating range, and that such capability can, however, be restricted at operating points corresponding to the lowest and highest values of active power output. The nonlinear characteristics of DRs can restrict the provision of POD at low wind speeds by preventing the OWFs from achieving zero active power output. Moreover, the consumption/production of reactive power, necessary to control the offshore AC network frequency, can reduce the active power headroom of the corresponding grid-forming WTs. This can restrict the provision of POD at high wind speeds by preventing the OWFs from achieving the maximum active power output.

Author Contributions: Conceptualisation, methodology: O.S.-R., Ö.G., L.Z. and N.A.C.; Funding acquisition: Ö.G. and N.A.C.; Supervision: Ö.G., L.Z. and N.A.C.; Writing—review and editing: Ö.G., L.Z., A.B. and N.A.C.; and Data curation, formal analysis, investigation, project administration, software, validation, visualisation, and writing—original draft: O.S.-R.

Funding: This work received funding from the European Union’s Horizon 2020 research and innovation programme under grant agreement No 691714.

Acknowledgments: The authors gratefully acknowledge the contributions of Jayachandra N. Sakamuri and Poul E. Sørensen to the discussions leading up to this work.

Conflicts of Interest: The authors declare no conflict of interest. The funders had no role in the design of the study; in the collection, analyses, or interpretation of data; in the writing of the manuscript, or in the decision to publish the results.

Nomenclature

The following abbreviations and symbols were used in this manuscript:

AC	Alternating-current
APC	Active power control
AVR	Automatic voltage regulator
C	WT FEC filter capacitance
CC	Current control
d axis	Direct axis
DC	Direct-current
DR	Diode rectifier
$\Delta\omega_{SM}$	SM (angular) speed deviation
ΔP_{on}	Onshore (active) power oscillation signal
$\Delta\hat{P}$	WF APC oscillatory/modulating (active) power signal
$\Delta\hat{P}_{CL}$	WF APC oscillatory/modulating (active) power internal/closed-loop signal
$\Delta\hat{P}_{OL}$	WF APC oscillatory/modulating (active) power external/open-loop signal
f_{OL}	WF APC oscillatory/modulating (active) power external/open-loop signal frequency
F_{POD}	WF POD control mode flag
FC	Frequency control
FEC	(WT) Front-end converter
HV	High-voltage
$I_{d,k}$	WT_k output d axis current
I_k	WT_k output current
$I_{q,k}$	WT_k output q axis current
$I_{T,k}$	WT_k FEC output current
$I_{Td,k}$	WT_k FEC output d axis current
$I_{Tq,k}$	WT_k FEC output q axis current
$I_{Td,k}^*$	WT_k FEC output d axis current reference
$I_{Tq,k}^*$	WT_k FEC output q axis current reference
k_{Fi}	WF APC PI regulator integral gain
k_{Fp}	WF APC PI regulator proportional gain
k_{Fi}	WT FEC CC PI regulator integral gain
k_{Ip}	WT FEC CC PI regulator proportional gain
k_{Li}	WT_k FEC PLL PI regulator integral gain
k_{Lp}	WT_k FEC PLL PI regulator proportional gain
k_O	WF APC POD phase lead compensator gain
k_ω	WT FEC FC P regulator gain
k_{Pi}	WT FEC APC PI regulator integral gain
k_{POD}	WF APC POD main gain
k_{Pp}	WT FEC APC PI regulator proportional gain
k_Q	WT FEC RPC P regulator (reactive-power-frequency droop) gain
k_{Ui}	WT FEC VC PI regulator integral gain
k_{Up}	WT FEC VC PI regulator proportional gain

κ_{disp}	WF active power dispatch coefficient
L	WT FEC filter inductance
LPF	Low-pass filter
OTS	Offshore transmission system
OWF	Offshore wind farm
ω	Offshore AC network (angular) frequency
ω_0	Offshore AC network (angular) frequency set point
ω_k	WT _k FEC (angular) frequency
ω_k^*	WT _k FEC (angular) frequency reference
P	Proportional (controller/regulator)
P_{ava}	Overall aerodynamic power available from the wind
$P_{\text{ava},k}$	Aerodynamic power from the wind available to WT _k
P_F	WF active power output
P_k	WT _k active power output
P_{on}	Onshore active power
$P_{T,k}$	WT _k FEC active power output
P^*	WF active power dispatch
P_F^*	WF active power (output) reference
$P_{T,k}^*$	WT _k FEC active power (output) reference
\hat{p}	WF APC PI regulator output (control) signal
PI	Proportional-integral (controller/regulator)
PLL	Phase-locked loop
POD	Power oscillation damping
pu	Per unit
PWM	Pulse width modulation
q axis	Quadrature axis
Q_F	WF reactive power output
Q_k	WT _k reactive power output
$Q_{T,k}$	WT _k FEC reactive power output
$Q_{T,k}^*$	WT _k FEC reactive power (output) reference
R	WT FEC filter resistance
RMS	Root mean square
RPC	Reactive power control
RRF	Rotating reference frame
s	Complex frequency variable
SM	Synchronous machine
t	Time variable
T_F	WF APC active power measurement filter time constant
T_{Op}	WF APC POD phase lead compensator pole time constant
T_{Oz}	WF APC POD phase lead compensator zero time constant
θ_k	WT _k FEC phase angle
U_0	Offshore AC network voltage set point
U_k	WT _k terminal RMS voltage
$U_{T,k}$	WT _k FEC filter capacitor voltage
$U_{Td,k}$	WT _k FEC filter capacitor d axis voltage
$U_{Tq,k}$	WT _k FEC filter capacitor q axis voltage
$U_{W,k}$	WT _k FEC voltage
$U_{Td,k}^*$	WT _k FEC filter capacitor d axis voltage reference
$U_{Tq,k}^*$	WT _k FEC filter capacitor q axis voltage reference
$U_{W,k}^*$	WT _k FEC voltage reference
$U_{Wd,k}^*$	WT _k FEC d axis voltage reference
$U_{Wq,k}^*$	WT _k FEC q axis voltage reference
VC	Voltage control
VSC	Voltage source converter
WF	Wind farm
WT _[k]	[kth] Wind turbine(s)
z^{-1}	Delay of one simulation time step

Appendix A

Table A1. Wind farm active power control parameters and limits.

Parameter	Value	Parameter	Value	Parameter	Value	Parameter	Value
k_{Fi}	5 pu/s [†]	k_O	7.65×10^{-3} pu	T_F	10 ms [†]	T_{Op}	13.9 ms
k_{Fp}	1×10^{-3} pu [†]	k_{POD}	5 pu	T_{Oz}	1.82 s		
Limits:	$0 \leq P^* \leq 1.1$ pu , -1.26 pu/s $\leq dP^*/dt \leq 1.26$ pu/s , -0.1 pu $\leq \Delta\hat{P} \leq 0.1$ pu						

[†] Not relevant to the simulations in question.

References

1. CIGRÉ Working Group B4.55. *HVDC Connection of Offshore Wind Power Plant*; Technical brochure 619; CIGRÉ: Paris, France, May 2015. Available online: <https://e-cigre.org/publication/619-hvdc-connection-of-offshore-wind-power-plants> (accessed on 29 August 2019).
2. Bresesti, P.; Kling, W.L.; Hendriks, R.L.; Vailati, R. HVDC Connection of Offshore Wind Farms to the Transmission System. *IEEE Trans. Energy Convers.* **2007**, *22*, 37–43. [CrossRef]
3. Van Hertem, D.; Gomis-Bellmunt, O.; Liang, J. (Eds.) *HVDC Grids: For Offshore and Supergrid of the Future*; John Wiley & Sons: Hoboken, NJ, USA, 2016.
4. ABB. *HVDC Light: It's Time to Connect*; Technical report; ABB: Zurich, Switzerland, March 2013. Available online: <https://new.abb.com/docs/default-source/ewea-doc/hvdc-light.pdf> (accessed on 29 August 2019).
5. CIGRÉ Working Group B4.37. *VSC Transmission*; Technical brochure 269; CIGRÉ: Paris, France, April 2005. Available online: <https://cigreindia.org/CIGRE%20Lib/Tech.%20Brochure/269%20VSC%20Transmission.pdf> (accessed on 29 August 2019).
6. Blasco-Giménez, R.M.; Añó-Villalba, S.C.; Rodríguez-D'Erlee, J.; Morant-Anglada, F.; Bernal-Pérez, S.I. Distributed Voltage and Frequency Control of Offshore Wind Farms Connected With a Diode-Based HVdc Link. *IEEE Trans. Power Electron.* **2010**, *25*, 3095–3105. [CrossRef]
7. Blasco-Giménez, R.M.; Añó-Villalba, S.C.; Rodríguez-D'Erlee, J.; Bernal-Pérez, S.I.; Morant-Anglada, F. Diode-Based HVdc Link for the Connection of Large Offshore Wind Farms. *IEEE Trans. Energy Convers.* **2011**, *26*, 615–626. [CrossRef]
8. Bernal-Pérez, S.I.; Añó-Villalba, S.C.; Blasco-Giménez, R.M.; Rodríguez-D'Erlee, J. Efficiency and Fault Ride-Through Performance of a Diode-Rectifier- and VSC-Inverter-Based HVDC Link for Offshore Wind Farms. *IEEE Trans. Ind. Electron.* **2013**, *60*, 2401–2409. [CrossRef]
9. Christ, T.; Seman, S.; Zurowski, R. Investigation of DC Converter Nonlinear Interaction with Offshore Wind Power Park System. In Proceedings of the 2015 EWEA Offshore Conference, Copenhagen, Denmark, 10–12 March 2015.
10. Menke, P.; Zurowski, R.; Christ, T.; Seman, S.; Giering, G.; Hammer, T.; Zink, W.; Hacker, F.; Imamovic, D.; Thisted, J.; et al. 2nd Generation DC Grid Access for Large Scale Offshore Wind Farms. In Proceedings of the 14th Wind Integration Workshop, Brussels, Belgium, 20–22 October 2015.
11. Yu, L.; Li, R.; Xu, L. Distributed PLL-Based Control of Offshore Wind Turbines Connected with Diode-Rectifier-Based HVDC Systems. *IEEE Trans. Power Deliv.* **2018**, *33*, 1328–1336. [CrossRef]
12. Saborío-Romano, O.; Bidadfar, A.; Göksu, Ö.; Altin, M.; Cutululis, N.A.; Sørensen, P.E. Connection of OWPPs to HVDC networks using VSCs and Diode Rectifiers: an Overview. In Proceedings of the 15th Wind Integration Workshop, Vienna, Austria, 15–17 November 2016.
13. PROMOTioN. *Deliverable 3.1: Detailed Functional Requirements to WPPs*; Project deliverable; PROMOTioN: Arnhem, The Netherlands, December 2016. Available online: https://www.onlines3.eu/wp-content/uploads/deliverables/ONLINES3_WP1%20D.1.1%20Specifications.pdf (accessed on 29 August 2019).
14. Domínguez-García, J.L.; Gomis-Bellmunt, O.; Bianchi, F.D.; Sumper, A. Power oscillation damping supported by wind power: A review. *Renew. Sustain. Energy Rev.* **2012**, *16*, 4994–5006. [CrossRef]
15. Knüppel, T.; Nielsen, J.N.; Jensen, K.H.; Dixon, A.; Østergaard, J. Power oscillation damping capabilities of wind power plant with full converter wind turbines considering its distributed and modular characteristics. *IET Renew. Power Gener.* **2013**, *7*, 431–442. [CrossRef]

16. Domínguez-García, J.L.; Ugalde-Loo, C.E.; Bianchi, F.D.; Gomis-Bellmunt, O. Input–output signal selection for damping of power system oscillations using wind power plants. *Electr. Power Energy Syst.* **2014**, *58*, 75–84. [CrossRef]
17. Zeni, L.; Eriksson, R.; Goumalatsos, S.; Altin, M.; Sørensen, P.; Hansen, A.D.; Kjær, P.; Hesselbæk, B. Power Oscillation Damping From VSC–HVDC Connected Offshore Wind Power Plants. *IEEE Trans. Power Deliv.* **2016**, *31*, 829–838. [CrossRef]
18. Pipelzadeh, Y.; Chaudhuri, N.R.; Chaudhuri, B.; Green, T.C. Coordinated Control of Offshore Wind Farm and Onshore HVDC Converter for Effective Power Oscillation Damping. *IEEE Trans. Power Syst.* **2017**, *32*, 1860–1872. [CrossRef]
19. PROMOTioN. *Deliverable 3.5: Performance of Ancillary Services Provision from WFs Connected to DR-HVDC*; Project deliverable; PROMOTioN: Arnhem, The Netherlands, January 2018. Available online: https://orbit.dtu.dk/files/163308588/D3.5_PROMOTioN_Performance_of_ancillary_services_provision_from_WFs_connected_to_DR_HVDC.pdf (accessed on 29 August 2019).
20. PROMOTioN. *Deliverable 3.2: Specifications of the Control Strategies and the Simulation Test Cases*; Project deliverable; PROMOTioN: Arnhem, The Netherlands, March 2017. Available online: https://www.promotion-offshore.net/news_events/news/detail/deliverable-32-specifications-of-the-control-strategies-and-the-simulation-test-cases/ (accessed on 29 August 2019).
21. Muljadi, E.; Pasupulati, S.; Ellis, A.; Kostrov, D. Method of Equivalencing for a Large Wind Power Plant with Multiple Turbine Representation. In Proceedings of the IEEE PES 2008 General Meeting, Pittsburgh, PA, USA, 20–24 July 2008.
22. National Grid. *The Grid Code—Issue 5, Revision 19*; Network code; National Grid: Warwick, UK, September 2016. Available online: <https://www.nationalgrideso.com/document/34091/download> (accessed on 29 August 2019).
23. Göçmen, T.; van der Laan, P.; Réthoré, P.E.; Peña-Díaz, A.; Larsen, G.C.; Ott, S. Wind turbine wake models developed at the technical university of Denmark: A review. *Renew. Sust. Energy Rev.* **2016**, *60*, 752–769. [CrossRef]



© 2019 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (<http://creativecommons.org/licenses/by/4.0/>).